


# CO<sub>2</sub> Component Description

## Discharge Delays


Effective: April 2002

K-81-5210

PART NUMBER	AGENT	NOMINAL DELAY TIME APPROX.	TYPE OF METERING TUBE
871071	CO <sub>2</sub>	30	CURLED
897636	CO <sub>2</sub>	60	CURLED
896677	360 PSI HALON 1301	25	NONE (ORIFICE ONLY)



INLET AND OUTLET MAY BE REDUCED WITH BUSHING OR BELL REDUCER AND NIPPLE TO 1/2" NPT IF NECESSARY.



### MATERIALS

**PRESSURE ACCUMULATOR: STEEL**

**METERING TUBE: STAINLESS STEEL**

**VALVE BODY: BRASS**

**FINISH: RED PAINT**

**FRICITION LOSS: 15 EQUIVALENT FEET OF 3/4" PIPE**

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL INC., Ashland, MA 01721. Telephone: (508) 881-2000

Kidde Fire Systems  
 400 Main Street  
 Ashland, MA 01721 USA  
 Tel: (508) 881-2000  
 Fax: (508) 881-8920  
<http://www.kiddefiresystems.com>