



MANUAL PULL

DESCRIPTION

The Fike Fire Alarm Pull Station (02-3710) and Releasing Manual Pull Station (20-128) are high quality all metal units. The manual pull station uses a SPST switch connected to a terminal strip for quick field installation. The activation switch is a normally open contact rated for 2.5A, 120/250V that closes when the station is activated.

OPERATION

Raising the hinged outer cover and pulling down on the front cover operates the double action station. The hanging cover displays positive indication and may only be reset with the supplied key.

MOUNTING

Surface Mounting: Use mounting box with minimum 3/4" depth
Semi-Flush Mounting: Use standard back box

SPECIFICATIONS

Switch: SPST 2.5 Amp 120/250V
Nominal Size: 5"H x 3"W x 1"D
Color: Red (02-3710 has raised white lettering)

ENGINEERING SPECIFICATIONS

Manual Station shall be of metal construction. Manual Stations shall be UL listed. The station shall be double action and action and activated by a pull on the front cover. When activated cover shall hang down to give indication of activation. A key shall be required to reset the station.

LABELS FOR RELEASING MANUAL PULL

The Releasing Manual Pull Station includes a set of three labels for field installation (labels should be placed on the face of the pull station between the Fike logo and the reset key).

Size: 2"W x 1"H
Wording: Watermist, HFC-227ea, CO₂

ORDERING INFORMATION

Fike P/N	Description
20-128	Releasing Manual Pull Station
02-3710	Fire Alarm Pull Station
02-10137	Optional sign: HFC-227ea System Release/Manual Pull Station
02-10312	Optional sign: HFC-125 System Release/Manual Pull Station
02-10102	Replacement Key



P/N 02-3710

APPROVALS

- UL Listed - S4874 (P/N 02-3710)
- S6239 (P/N 20-128)
- CSFM - 7150-1137:101 (P/N 02-3710)
(P/N 20-128)

(This page is left blank intentionally)



Copyright © Fike Corporation All Rights Reserved.
Form No. P.1.12.01-2 September, 2005 Specifications are subject to change without notice.
